

EXHIBIT 17

Jason Evans

From: Jason Evans
Sent: Tuesday, September 21, 2010 4:17 PM
To: 'PAtasoy@aol.com'
Cc: 'Iannotti, Jason'; Jim Counihan; John Loftus
Subject: 2300 PA Ave Subst Compl Punchlist Sign-Off
Attachments: SKMBT_60010092014150.pdf

Pelin,

Good afternoon. It has been requested that I schedule you to re-inspect the attached punchlist items for an official sign-off. Could you please let me know when you are available to meet at the site and sign-off on the items?

Thank you,

Jason Evans
Project Engineer
HARKINS BUILDERS, INC.
(410) 480-4199
www.harkinsbuilders.com



Celebrating 45 Years of Construction Excellence

> COMMERCIAL > MIXED USE > MULTIFAMILY > HEALTHCARE > STUDENT HOUSING > SENIOR LIVING > MILITARY

Follow us on [Facebook](#) and [Twitter](#)

2300 Pennsylvania Ave Apartments
Substantial Completion Punchlist

- | # | Issue |
|----|--|
| 1 | RTU1 Install for future kitchen (does it meet distance requirements for code?) <i>COMPLETE - verified by HVAC sub</i> |
| 2 | Remove temp. power for swing stages <i>COMPLETE</i> |
| 3 | Install FOB on electric room 2 <i>COMPLETE</i> |
| 4 | Install FOB on elevator room <i>COMPLETE</i> |
| 5 | Install Mag Lock on rear gate <i>COMPLETE</i> |
| 6 | Dimension at push side of the stair doors should be 1'0" See SK-286 <i>NEW ASK. Framing in per plan. NOT HBI.</i> |
| 7 | Repair, replace deficient parts of windows provide final test reports showing windows are rated HC 70 <i>- TO BE COMPLETE 9/23</i> |
| 8 | Provide warranty bond for windows <i>- SENT TO OWNER 9/3/10, AWAITING RESPONSE</i> |
| 9 | Finalize leakage issues at garage walls <i>COMPLETE. DISCUSSED BETWEEN TREC. and DICKL.</i> |
| 10 | Resolve green roof exposed piping issues and planting issues <i>- WARRANTY / MAINTENANCE ITEM. MATERIAL SETTLEMENT.</i> |
| 11 | Replace ballasts and bulbs in garage lights <i>- WARRANTY ITEM. ELECTRICAL SUB TO COMPLETE 9/20.</i> |

No info. filled in on G704 cert. of subst. compl. ?